WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83342
Permit No.
Basin 91

NOTICE OF INTENT NO. [redacted]

OWNER Paul Burr-Verdi Construction
MAILING ADDRESS P.O. Box 6
Verdi, NV 89439

ADDRESS AT WELL LOCATION 225 Bridge St.

2. LOCATION SE 1/4 SW 1/4 Sec. 8 T 19N N/S R 18E E Washoe County

PERMIT NO. WaCo#6662 Issued by Water Resources | 38-072-26 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Large rocks		3	36	33
Light brown clay/gravel		36	55	19
Grey clay		55	129	74
Green slate/clay	x	129	162	33
Grey clay		162	201	39
Coffee colored clay/rock	x	201	215	14

Date started 9/20/2000, 19__
Date completed 9/26/2000, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air lift	10-20		3 Hrs

8. WELL CONSTRUCTION
Depth Drilled ~~9/20/2000~~ 215 Feet Depth Cased ~~9/26/200~~ 215 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4"	Inches	0	Feet	105	Feet
9	Inches	105	Feet	215	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	+1	215

Perforations:
Type perforation Factory mill slot
Size perforation 3/32" x 3"
From 115 feet to 135 feet
From 195 feet to 215 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 105
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed [X] Yes [ ] No
From 105 feet to 215 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (by driller performing actual drilling on-site of contractor)
Date 9/29/00

USE ADDITIONAL SHEETS IF NECESSARY