WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83348
Permit No.
Basin 44

NOTICE OF INTENT [redacted]

OWNER OLGA F. BERROYER
MAILING ADDRESS HC 34 BOX 536-10
ELKO, NV 89801

ADDRESS AT WELL LOCATION Horsehaven Drive
BLOCK 21, LOT 6
~~Elko~~ Ryndon

2. LOCATION NW 1/4 NW 1/4 Sec. 1 T 35N N/S R 56 E ELKO County
PERMIT NO. Issued by Water Resources
030021006 Parcel No.
MEADOW VALLEY RANCHES #1 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	4	4
CALICHE CLAY		4	86	82
SANDSTONE	X	86	87	1
CLAY		87	122	35
SAND AND GRAVEL		122	132	10

RECEIVED 00 OCT 13 PM 12:00 STATE ENGINEER'S OFFICE

Date started 10/6/00, 19__
Date completed 10/9/00, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	50		3HRS

8. WELL CONSTRUCTION
Depth Drilled 132 Feet Depth Cased 132 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	132	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+1	132

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 111 feet to 132 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 54
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 54 feet to 132 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Company (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10-11-00