

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 83349  
 Permit No. \_\_\_\_\_  
 Basin 49

NOTICE OF INTENT NO. 45385

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER KEN MILLER ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. BOX 841 JOHNSON AVE  
CARLIN, NV 89822

2. LOCATION NE 1/4 NE 1/4 Sec. 36 T 36N N/S R 56E E ELKO County  
 PERMIT NO. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources 00633H009 Parcel No. \_\_\_\_\_

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other  Municipal/Industrial  Monitor  Stock  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SOFT SANDSTONE		0	184	184
HARD STONESTONE		184	196	2
FINE SAND	X	196	200	4
HARD SANDSTONE		200	206	6
LOOSE SAND	X	206	232	26

8. WELL CONSTRUCTION

Depth Drilled 232 Feet Depth Cased 232 Feet

HOLE DIAMETER (BIT SIZE)

From \_\_\_\_\_ To \_\_\_\_\_  
10 5/8 Inches 0 Feet 232 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8"</u>	<u>12.92</u>	<u>188</u>	<u>+2</u>	<u>232</u>

Perforations:  
 Type perforation MILL SLOT  
 Size perforation 3/16" X 3"

From 212 feet to 232 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 53  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 53 feet to 232 feet

9. WATER LEVEL

Static water level 140 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 11/21/00, 19\_\_\_\_  
 Date completed 11/28/00, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>4.5 HRS</u>

Name Fertig Drilling Company Contractor  
 Address P.O. BOX 525 Contractor  
ELKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shad C Fertig  
 By driller performing actual drilling on-site or contractor  
 Date 11-28-00