

OFFICE USE ONLY
 Log No. 83357
 Permit No. _____
 Basin 91
 NOTICE OF INTENT NO. 45034

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Mr. & Mrs. B. Kelly ADDRESS AT WELL LOCATION 447 Dusty Lane
 MAILING ADDRESS c/o Brasher 2435 Faretto Lane Verdi, Nevada
Reno, Nevada 89511
 2. LOCATION NW 1/4 SE 1/4 Sec. 18 T 19N N/S R. 18 E Washoe County
 PERMIT NO. 038-082-19 Verdi area
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown clay w/boulder, gravel & sand		2	10	8
Brown sandy clay		10	13	3
Dark brown sandy clay		13	21	8
Light gray sandy clay		21	27	6
Gray sandy clay		27	57	30
Dark brown sandy clay		57	66	9
Gray sandy clay		66	106	40
Soft zone	X	106	109	3
Gray sandy clay		109	142	33
Soft zone	X	142	146	4
Gray sandy clay		146	148	2
Soft zone	X	148	150	2
Gray sandy clay		150	152	2
Soft zone	X	152	153	1
Gray sandy clay		153	166	13
Soft zone	X	166	167	1
Gray sandy clay		167	171	4
Soft zone	X	171	172	1
Gray sandy clay		172	177	5
Soft zone	X	177	179	2
Gray sandy clay		179	194	15
Soft dark brown sandy clay		194	199	5
Gray sandy clay		199	200	1
Soft zone	X	200	204	4
Gray sandy clay		204	216	12
Soft zone	X	216	220	4
Gray sandy clay		220	232	10

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/9 Inches To 0 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8"</u>		<u>.188</u>	<u>0</u>	<u>250</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 238 feet to 138 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 250 feet

9. WATER LEVEL
 Static water level 39 feet below land surface
 Artesian flow _____ G.P.M. 100+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Date started September 11, 2000 19_____
 Date completed September 19, 2000 19_____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>100+</u>		
Dark gray volcanic rock		<u>232</u>	<u>236</u> 4
Soft zone		<u>X</u> <u>236</u>	<u>240</u> 4
Dark gray sandy clay		<u>240</u>	<u>250</u> 10

Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date September 22, 2000