554

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

MO 2000-8

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 3337
Permit No. 378
Basin

NOTICE OF INTENT NO. 45372

1. OWNER Round Mountain Gold Corporation
MAILING ADDRESS P.O. Box 480
Round Mountain Nevada 89045

ADDRESS AT WELL LOCATION Round Mountain Gold Corporation Pit

2. LOCATION NE ¼ SE ¼ Sec. 24 T. 10 N/S R. 43 E. Nye County

PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granet Alluvium		0	1050	1050'
2" Casing From		+1	1051	1050'
1" Casing From		+1	974	973'
1" Casing From		+1	900	901'
Neat Cement		0	26'	26'
3/8 Hole plug		26'	511'	485'
Sand Pack		511'	900'	389'
Cement Seal		900	920'	20
Sand Pack		920'	974'	54'
Cement Seal		974'	979	5'
Sand Pack		979'	1051	72'

Date started 12-6, 2000
Date completed 1-12, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
585'	13		5min.
605'	12		5Min.
705'	25		5Min.
805'	33		5Min.
905	43		5Min.
1005'	50		5Min.
1050	50		5Min.

8. WELL CONSTRUCTION
Depth Drilled 1050' Feet Depth Cased 1051 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14"	Inches	0	Feet	40'	Feet
8¾"	Inches	40'	Feet	545	Feet
8½"	Inches	545	Feet	1050'	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10¾		3/16 wall	+1	40'
2"		SCH 40	+2	1051'
1"		SCH 40	+1	974'
1"		SCH 40	+1	900'

Perforations:
Type perforation Lawver
Size perforation .020
2" From 991 feet to 1031' feet
1" From 934' feet to 954' feet
1" From 860' feet to 880' feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 511' feet to 1051 feet

9. WATER LEVEL
Static water level 447 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co. Contractor
Address P.O. Box 2748 Contractor
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1786
Signed Craig Diner By driller performing actual drilling on site or contractor
Date 1-12-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627