WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83377
Permit No.
Basin 40

NOTICE OF INTENT NO. 447[illegible]

1. OWNER **NEVADA DEPT OF TRANSPORTATION**
MAILING ADDRESS **1951 IDAHO STREET**
ELKO, NV 89801

ADDRESS AT WELL LOCATION **CONTACT MAINTENANCE STATION, CONTACT, NV**

2. LOCATION **NE** 1/4 **SW** 1/4 Sec. **20** T **45N** N/S R **64E** E **ELKO** County
PERMIT NO. **~~NDOT~~ 66540** Issued by Water Resources | Parcel No. | **TRACT OF LAND** Subdivision Name

3. **WORK PERFORMED**
New Well | Replace | Recondition | X Abandon
Deepen | X Abandon | Other

4. **PROPOSED USE**
X Domestic | Irrigation | Test
Municipal/Industrial | Monitor | Stock

5. **WELL TYPE**
Cable | Rotary | RVC
Air | Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
REMOVE SUBMERSIBLE PUMP				
SET 60' OF TREMIE PIPE				
PUMP CEMENT TO SURFACE				
USE 14 BAGS OF CEMENT WITH 2% BENTONITE				
WATER LEVEL WAS 25' BEFORE PLUGGING				
THIS WELL WAS IN A BUILDING SO WE OBTAINED A WAIVER FOR SECTION 534.420 (5) FROM TIM WILSON				

RECEIVED 01 FEB -5 PM 12:24 STATE ENGINEERS OFFICE

Date started **01/30/2001**, 19__
Date completed **01/30/2001**, 19__

7. **WELL TEST DATA**
TEST METHOD: Bailer | Pump | Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled Feet Depth Cased **63** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	63

Perforations:
Type perforation **N/A**
Size perforation **N/A**

From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes | X | No
Depth of Seal
Placement Method: Pumped | Poured
Seal Type: Neat Cement | Cement Grout | Concrete Grout

Gravel Packed: Yes | X | No
From **N/A** feet to **N/A** feet

9. **WATER LEVEL**
Static water level **25'** feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **HACKWORTH DRILLING, INC** Contractor
Address **P.O.BOX 850** Contractor
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board **020582**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1689**
Signed [signature] By driller performing actual drilling on-site or contractor
Date **02/01/2001**

USE ADDITIONAL SHEETS IF NECESSARY