WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83412
Permit No.
Basin 105

NOTICE OF INTENT NO. 20324

1. OWNER K.G. Walters
MAILING ADDRESS Santa Rosa CA
ADDRESS AT WELL LOCATION 1790 Hwy 395
Minden NV 89423

2. LOCATION ¼ ¼ Sec. 30 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. DFW-25 Issued by Water Resources
1320-30-101-001 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pull Casing				
grut pack to 10'				
Cap w/ cement grout				
9 wells abandon				
in this Parcel				

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	45 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	PVC	Sch 40	0	45

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 10 feet to 45 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering Corp Contractor
Address 536 E Maitland Contractor
Ontario CA 91761
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968
Signed By driller performing actual drilling on site or contractor
Date 3-28-01

Date started 3-28-01, 19
Date completed 3-28-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
01 MAR 29 AM 8:19
WATER ENGINEERING DIVISION

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627