

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43262

OWNER Barrick Goldstrike Mines PZ99-17 ADDRESS AT WELL LOCATION Barrick Goldstrike  
 MAILING ADDRESS P.O. Box 29 minesite, north of Carlin, NV.  
Elko, NV 89803

2. LOCATION NE 1/4 SW 1/4 Sec. 19 T 36N N/S R 50E E Eureka County  
 PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>Abandoned by pumping neat cement from T.D. to surface.</b>				
<b>Quantities Used:</b>				
<b>#1: 14 cu.ft.</b>				
<b>#2: 9 cu.ft.</b>				
<b>Original Construction Detail:</b>				
<b>Cement</b>		<b>0</b>	<b>25</b>	<b>25</b>
<b>Hole plug</b>		<b>25</b>	<b>210</b>	<b>185</b>
<b>Gravel</b>		<b>210</b>	<b>242</b>	<b>32</b>
<b>Hole plug</b>		<b>242</b>	<b>343</b>	<b>101</b>
<b>Cement</b>		<b>343</b>	<b>361</b>	<b>18</b>
<b>Hole plug</b>		<b>361</b>	<b>370</b>	<b>9</b>
<b>Gravel</b>		<b>370</b>	<b>410</b>	<b>40</b>

RECEIVED  
 OCT 26 AM 11:29  
 STATE ENGINEERING OFFICE

Date started 10/20/2000, 19\_\_\_\_  
 Date completed 10/20/2000, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

8. WELL CONSTRUCTION  
 Depth Drilled 410 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 14.750 Inches To 0 Feet 25 Feet  
 From 8.875 Inches To 25 Feet 410 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10.750</u>	<u>28.04</u>	<u>0.250</u>	<u>0</u>	<u>25</u>
<u>1: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>400</u>
<u>2: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>240</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 0.125" X 3"  
 From 1: 380 feet to 400 feet  
 From 2: 220 feet to 240 feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 25'  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From See Detail feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 1: 315.9 2: Dry feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Lang Exploratory Drilling Contractor  
 Address P.O. Box 5279 Contractor  
Elko, NV 89802-5279  
 Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1888  
 Signed David R. Riviot  
 By driller performing actual drilling on-site or contractor  
 Date 10/23/00

BSTC