Beylik Job #: 41202

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83460
Permit No.
Basin 84

NOTICE OF INTENT NO. 19923

1. OWNER The Boeing Co., Rocketdyne
MAILING ADDRESS 6633 Canoga Ave.
Canoga Park, CA 91303

ADDRESS AT WELL LOCATION
5600 Whiskey Springs Rd.
Reno, NV 89510-9765

2. LOCATION SE ¼ NE ¼ Sec. 6 T. 22 N/S R. 21 E. Washoe County
PERMIT NO. Issued by Water Resources
76-242-05 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other drive cas.

6. E1-A LITHOLOGIC LOG #2

Material	Water Strata	From	To	Thickness
Sand Rock		-0-	75	75
Sand Boulders Rock		75	90	15
Sand Small Rock		90	120	30
Sand Small Rock, Boulders		120	170	50

Date started October 02, 2000, 19 X
Date completed October 04, 2000, 19 X

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		-0- Feet	170 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	M.S.	.250	-0-	115
4.5	PVC	Sch40	115	165

Perforations:
Type perforation Mill Slot
Size perforation .020
From 115 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 108
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 108 feet to 170 feet

9. WATER LEVEL
Static water level 136.4 feet below land surface
Artesian flow no G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Stratton for Beylik Drilling (Contractor)
Address 555 S. Harbor Blvd. (Contractor)
La Habra, CA 90631-6124
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011
Signed Donald C Stratton (By driller performing actual drilling on site or contractor)
Date October 26, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627