Job #: 41243

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 8347
Permit No. 66868
Basin 105

NOTICE OF INTENT NO. 4603

1. OWNER Douglas Co. Comm. Servi. Dist.
MAILING ADDRESS 1594 Esmeralda Ave.
Minden, NV 89423

ADDRESS AT WELL LOCATION
Douglas County Airport, South End
Hayborne Rd.

2. LOCATION SE ¼ NE ¼ Sec. 17 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. 66868 (Issued by Water Resources) 1320-08-004 (Parcel No.) Douglas County So. Airport (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		-0-	25	25
Clay & Silty Clay	no	25	40	15
Sand & Gravel	yes	40	255	215
Clayey Gravel	no	255	265	10
Sand & Gravel	yes	265	375	100
Clay	no	375	385	10
Sandy Gravel	yes	385	405	20
Clay	no	405	410	5
Sand & Gravel	yes	410	420	10

Date started April 01, 2001
Date completed April 30, 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Constant	1800	83	24

8. WELL CONSTRUCTION
Depth Drilled 430 Feet Depth Cased 405 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	30	Feet	430	Feet
36	Inches	GL	Feet	30	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	83	.5	+1	30
16	63	.375	+2	405

Perforations:
Type perforation Wire Wrap
Size perforation .065
From 150 feet to 230 feet
From 265 feet to 285 feet
From 350 feet to 370 feet
From 385 feet to 405 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 127
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 430 feet to 130 feet

9. WATER LEVEL
Static water level 5.15 feet below land surface
Artesian flow -0- G.P.M. P.S.I.
Water temperature 63 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Beylik Drilling, Inc. (Contractor)
Address 555 S. Harbor Blvd. (Contractor)
La Habra, CA 90631-6124
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011
Signed Donald C. Stratton (By driller performing actual drilling on site or contractor)
Date May 02, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627