

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83468
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **45853**

1. OWNER **KIM POSNIEN CONSTRUCTION**
 MAILING ADDRESS **440 FOOTHILLS RD**
GARDNERVILLE, NV 89410
 ADDRESS AT WELL LOCATION **195 ASPEN HILL RD**
GARDNERVILLE, NV 89410

2. LOCATION SW $\frac{1}{4}$ SW $\frac{1}{4}$ Sec 3 T 12 N R 19 E **DOUGLAS** County

PERMIT NO. **13-032-2010** **FOOTHILLS RD**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVERBURDEN		0	3	3
DARK BROWN SILTY SAND		3	21	18
COURSE DG SANDS & GRANITE COBBLES		21	78	57
LIGHT BROWN DG SANDS AND CLAY STRATAS		78	169	91
BROWN CLAY		169	193	24
COURSE FRACTURED DG SANDS	XXX	193	220	27

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 3/4 Inches 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	220

Perforations:
 Type perforation **FACTORY MILL SLOT**
 Size perforation **3X 3/32**
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60 feet to 220 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature **COLD** °F Quality **GOOD**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 3/29, 20 01
 Date completed 3/31, 20 01

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25</u>	<u>35</u>	<u>3 HRS</u>	

Name **CAPITAL CITY WELL DRILLING**
 (CONTRACTOR)
 Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board **41775**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**
 Signed Michael J. Black
 By driller performing actual drilling on site or contractor
 Date 3/31/01

RECEIVED
 0 APR -2 11 9:00
 WATER ENGINEERING OFFICE