

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 83469
 Permit No. _____
 Basin 104
 NOTICE OF INTENT NO. 42029

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

1. OWNER **ELENORE DOYLE**
 MAILING ADDRESS **4249 EMERSON DR**
CARSON CITY, NV 89701
 ADDRESS AT WELL LOCATION **4249 EMERSON DR**
CARSON CITY, NV 89701

2. LOCATION **NE NE** Sec. **5** T. **15** R. **20** E. **CARSON** County
 PERMIT NO. **08-113-14**
Issued by: Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other N/A

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8" WELL WAS LOCATED INSIDE A LARGE PUMP HOUSE		0	72	72
TAGGED BOTTOM PLACED TREEMING PIPE TO BOTTOM AND PRESSURE PUMPED WITH NEAT CEMENT 6 SACK TO 30 GALLON LEFT DOWN TWO FT				
APPLIED FOR WEIVER FROM MATT DILLION 2/24/01				

8. WELL CONSTRUCTION

Depth Drilled N/A Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

From	To
8 5/8 Inches	0 Feet 72 Feet
Inches	Feet Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Pt. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	15.25	.188	0	72

Perforations:

Type perforation **MILL SLOT**
 Size perforation **3 X 3/32**

From	To
52 feet to	72 feet
feet to	feet
feet to	feet
feet to	feet
feet to	feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **45** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From N/A feet to N/A feet

9. WATER LEVEL

Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. 5 P.S.I.
 Water temperature COLD °F Quality POOR

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **CAPITAL CITY WELL DRILLING**
(CONTRACTOR)

Date started 3/1, 20 01
 Date completed 3/1, 20 01

7. WELL TEST DATE

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A	N/A	N/A

Address **20 KIT KAT DRIVE**
(CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board **41775**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**
 Signed Michael Black
 By driller performing actual drilling on site or contractor
 Date 3/1/01