

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83471
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45850

1. OWNER **MIKE NEUENS**
 MAILING ADDRESS **577 LEE ALLEN CIRCLE**
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION **577 LEE ALLEN CIRCLE**
GARDNERVILLE, NV 89410

2. LOCATION SW $\frac{1}{4}$ SW $\frac{1}{4}$ Sec 25 T 12 N R 19 E DOUGLAS County
 PERMIT NO. 19-410-020

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVERBURDEN		0	4	4
COURSE DG SANDS		4	12	8
HARD GRANITE BOULDER		12	39	27
COURSE DG SANDS		39	63	24
FRACTURED GRANITE BOULDERS		63	125	62
SMALL DG SANDS COURSE GRANITE	XXX	125	145	20

8. WELL CONSTRUCTION
 Depth Drilled 145 Feet Depth Cased 145 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 145 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	145

Perforations:
 Type perforation **FACTORY MILL SLOT**
 Size perforation 3 X 3/32
 From 125 feet to 145 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 145 feet

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 3/26, 20 01
 Date completed 3/27, 20 01

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>	<u>30</u>	<u>3 HRS</u>

Name **CAPITAL CITY WELL DRILLING**
 (CONTRACTOR)
 Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael L. Beck
 By driller performing actual drilling on site or contractor
 Date 3/28/01

RECEIVED
 01 APR - 2 AM 9:00
 STATE ENGINEERS OFFICE