

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 83472  
 Permit No. \_\_\_\_\_  
 Basin 105  
 NOTICE OF INTENT NO. **45851**

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **GREG DAVIES CONSTRUCTION** ADDRESS AT WELL LOCATION **1747 MERINO CIRCLE**  
 MAILING ADDRESS **P.O. BOX 22** **GARDNERVILLE, NV 89410**

2. LOCATION NE 1/4 NE 1/4 Sec 14 T 12 N R 20 E **DOUGLAS** County  
 PERMIT NO. 1220-14-010-008

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVERBURDEN		0	3	3
LARGE COBBLES		3	68	65
COURSE OBSIDIAN GRAVELS		65	91	23
BROWN CLAY STRATA		91	137	46
COURSE SANDS AND GRAVELS SLATE, VOLCANIC GRAVELS		137	170	33
LARGE COBBLES AND OBSIDIAN GRAVELS	XXX	170	190	20

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 0 Feet 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	190

Perforations:  
 Type perforation **FACTORY MILL SLOT**  
 Size perforation 3 X 3/32  
 From 170 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 190 feet

Date started 3/24, 20 01  
 Date completed 3/26, 20 01

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>35</u>	<u>3 HRS</u>

9. WATER LEVEL  
 Static water level 85 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **CAPITAL CITY WELL DRILLING**  
 (CONTRACTOR)  
 Address **20 KIT KAT DRIVE**  
 (CONTRACTOR)  
**CARSON CITY, NV 89701**  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael J. Slack  
 By driller performing actual drilling on site or contractor  
 Date 3/26/01

RECEIVED  
 01 APR -2 AM 9:00  
 STATE ENGINEERS OFFICE