

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45281

1. OWNER Yerington Paiute Tribe ADDRESS AT WELL LOCATION Campbell Ranch  
 MAILING ADDRESS 171 Campbell Lane  
Yerington, NV 89447

2. LOCATION SW 1/4 SW 1/4 Sec. 16 T 14N N/S R 25E E Lyon County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand/clay		0	14	
sandy gravel		14	47	33
clay		47	52	5
sand & gravel		52	90	38
sand & gravel w/clay		90	93	3
clay		93	109	16
sand & gravel		109	113	4
clay		113	122	9
sand & gravel		122	133	11
clay		133	141	8
sand & gravel		141	148	7
clay		148	154	6
sand & gravel		154	183	29
clay		183	189	6
sand & gravel/cobbles		189	218	29
sand & gravel w/clay		218	221	3
sand & gravel		221	230	9
clay		230	246	16
sand & gravel		246	254	8
clay		254	257	3
sand & gravel w/clay		257	261	4
clay		261	280	19
sand & gravel w/cobbles		280	331	51
sand & gravel w/clay		331	333	2
sand/gravel/broken rock		333	372	39

Continued on next page

8. WELL CONSTRUCTION  
 Depth Drilled 438 Feet Depth Cased 437 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>36</u>	<u>0</u>	<u>50</u>		
<u>24</u>	<u>50</u>	<u>438</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>30</u>		<u>.250</u>	<u>0</u>	<u>5</u>
<u>30</u>		<u>corrugated</u>	<u>5</u>	<u>45</u>
<u>30</u>		<u>.250</u>	<u>45</u>	<u>50</u>
<u>16"</u>		<u>.250</u>	<u>0</u>	<u>74</u>

Perforations: Type perforation mill slot  
 Size perforation .090  
 From 74 feet to 114 double row feet  
 From 114 feet to 236 quad row feet  
 From 236 feet to 276 double row feet  
 From 276 feet to 398 quad row feet  
 From 398 feet to 438 double row feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 0 feet to 438 feet

9. WATER LEVEL  
 Static water level 20 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc.  
 Contractor  
 Address 4675 W. Winnemucca Blvd  
 Contractor

Date started 3/25/01, 19\_\_\_\_  
 Date completed 3/28/01, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift G.P.M. <u>4200</u>	<u>87</u>	<u>7.5 hrs.</u>

Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1572  
 Signed Jean A. Jones  
 by driller performing actual drilling on site or contractor  
 Date 4/2/01

