

Job #: 41185

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 23480
Permit No. _____
Basin. 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

Douglas County Sewer

1. OWNER Improvement Dist. ADDRESS AT WELL LOCATION Buckeye Creek Effluent Reuse Facility
MAILING ADDRESS P.O. Box 578 Minden, NV
Zephyr Cove, NV 89448
2. LOCATION SW 1/4 SW 1/4 Sec 18 T 13 N/S R 21 E MDB & M Douglas County
PERMIT NO. D0005 m/o 455 23-010-67 BLM Lands, Minden, NV
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. MW-22 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine Sand, Gravel				
Rock		-0-	48	48
Sand Gravel		48	93	45
Brown Sand	118	93	146	53
Sand and Gravel		146	158	12
Sand Gravel Rock		158	220	62
Silty Sand		220	223	3

8. WELL CONSTRUCTION
Depth Drilled 223 Feet Depth Cased 223 Feet
HOLE DIAMETER (BIT SIZE)
From To
10-3/4 Inches -0- Feet 50 Feet
6-5/8 Inches 50 Feet 223 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10-3/4</u>		<u>.250</u>	<u>-0-</u>	<u>50</u>
<u>6-5/8</u>		<u>.250</u>	<u>-0-</u>	<u>197</u>
<u>5</u>		<u>218</u>		<u>223</u>

Perforations:
Type perforation Screen M.S.
Size perforation .020
From 197 feet to 218 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 111.8 feet below land surface
Artesian flow NO G.P.M. _____ P.S.I. _____
Water temperature _____ °F Quality _____

Date started August 06, 2000
Date completed August 10, 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>50</u>	<u>147.63</u>	<u>2 hrs.</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Stratton for Beylik Drilling Contractor
Address 555 S. Harbor Blvd. Contractor
La Habra, CA 90631-6124
Nevada contractor's license number 0007055A
issued by the State Contractor's Board
Nevada driller's license number issued by the 2011
Division of Water Resources, the on-site driller
Signed Donald C. Stratton
By driller performing actual drilling on site or contractor
Date November 01, 2000