Beylik Job #: 41185

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83481
Permit No.
Basin 105

NOTICE OF INTENT NO.

1. OWNER Douglas County Sewer Improvement Dist.
MAILING ADDRESS P.O. Box 578
Zephyr Cove, NV 89448

ADDRESS AT WELL LOCATION 2120 Stockyard Rd.
Minden, NV

2. LOCATION SW ¼ SE ¼ Sec 18 T 13 N/S R 21 E MDB & M Douglas County

PERMIT NO. ~~D0005~~ MU 455 (Issued by Water Resources) | 23-010-68 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. MW-20 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel, Rock		-0-	51	51
Sand Gravel	73	51	76	25
Sand		76	86	10
Sand Gravel		86	181	95
Silty Sand, Some Clay		181	185	4

Date started July 30, 2000, 19X
Date completed August 02, 2000, 19X

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	145.60	2.5

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-3/4 Inches		-0- Feet	50 Feet
6-5/8 Inches		50 Feet	125 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10-3/4		.250	-0-	50
6-5/8		.250	50	162
5		.250	180	185

Perforations:
Type perforation Screen M.S.
Size perforation .020
From 159 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 68.5 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don Stratton for Beylik Drilling (Contractor)
Address 555 S. Harbor Blvd. (Contractor)
La Habra, CA 90631-6124

Nevada contractor's license number issued by the State Contractor's Board 0007055A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011

Signed Donald C. Stratton (By driller performing actual drilling on site or contractor)

Date October 31, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627