

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ....

Douglas County Sewer Improvement District

1. OWNER Douglas County Sewer Improvement District  
 MAILING ADDRESS P.O. Box 578  
Zephyr Cove, NV 89448

ADDRESS AT WELL LOCATION 2120 Stockyard Rd.  
Minden, NV

2. LOCATION SW 1/4 NW 1/4 Sec 17 T 13  
 PERMIT NO. D-000-5 M10 465 23-010-68

N/S R. 21 E MDB & M Douglas County  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other drive cas.

6. Well D LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, Gravel, Boulders		-0-	43	43
Sand, Gravel, Rock		43	60	17
Sand, Gravel, Silt, Sand	66'	60	208	145
Silty Sand, Some Clay		205	208	3

8. WELL CONSTRUCTION  
 Depth Drilled 208 Feet Depth Cased 208 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10-3/4 Inches -0- Feet 60 Feet  
6-5/8 Inches 60 Feet 208 Feet  
 .....Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10-3/4		.250	-0-	60
6-5/8		.250	-0-	186
5		.250	202	208

Perforations:  
 Type perforation Screen M.S.  
 Size perforation .020  
 From 186 feet to 202 feet  
 From ..... feet to ..... feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From ..... feet to ..... feet

9. WATER LEVEL  
 Static water level 62.6 feet below land surface  
 Artesian flow no G.P.M. .... P.S.I.  
 Water temperature cold °F Quality .....

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Don Stratton for Beylik Drilling  
 Contractor  
 Address 555 S. Harbor Blvd.  
 Contractor  
La Habra, CA 90631-6124  
 Nevada contractor's license number 0007055A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 2011  
 Division of Water Resources, the on-site driller  
 Signed Ronald C. Stratton  
 By driller performing actual drilling on site or contractor  
 Date October 26, 2000

Date started July 22, 2000   
 Date completed July 26, 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>159.15</u>	<u>2 hr.</u>