Job #: 41185

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83484
Permit No.
Basin 105

NOTICE OF INTENT NO.

1. OWNER Douglas County Sewer Improvement Dist.
MAILING ADDRESS P.O. Box 578
Zephyr Cove, NV 89448

ADDRESS AT WELL LOCATION 2120 Stockyard Rd.
Minden, NV

2. LOCATION SW ¼ SE ¼ Sec. 18 T 13 N/S R 21 E MDB & M Douglas County
PERMIT NO. ~~D0005~~ M/U 455 (Issued by Water Resources) | Parcel No. 23-101-68 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. MW-21 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel Rock		-0-	50	50
Sand Gravel Rock	65	50	71	21
Sand Gravel		71	206	135
Silty Sand		206	209	3

Date started August 02, 2000, Yo
Date completed August 05, 2000, Yo

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10.3	98.95	1.15

8. WELL CONSTRUCTION
Depth Drilled 209 Feet Depth Cased 209 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-3/4 Inches	-0- Feet	50 Feet
6-5/8 Inches	50 Feet	209 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10-3/4		.250	-0-	50
6-5/8		.250	-0-	188
5		.250	204	209

Perforations:
Type perforation Screen M.S.
Size perforation .020
From 183 feet to 204 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 63.2 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Stratton for Beylik Drilling (Contractor)
Address 555 S. Harbor Blvd. (Contractor)
La Habra, CA 90631-6124
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011
Signed Donald C Stratton (By driller performing actual drilling on site or contractor)
Date November 01, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627