WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83488
Permit No.
Basin 212

NOTICE OF INTENT NO. 20327

1. OWNER WELLS CARGO CONST.
MAILING ADDRESS 770 W SPRING MOUNTAIN Rd LV Nevada - 89117
ADDRESS AT WELL LOCATION 2650 S. LV BLVD LV, NV.

2. LOCATION SE ¼ NE ¼ Sec. 9 T 21 N S R 61 E CLARK County
PERMIT NO. DW-1137 (Issued by Water Resources) 162-09-613-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other BUCKET

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 0 - Sand/Gravel Mix | 6' | 0 | 6 | |
| Conglamorate | — | 6 | 7 | |
| Clay/Sand Mix w/ Gravel | — | 7 | 20 | |
| Sand/Clay Mix | — | 20 | 30 | |

WELL # 1 (N.E)




DCNR/DWR Received JUN 27 2001 LAS VEGAS OFFICE

Date started 6-26-01 19 01
Date completed 6-26-01 19 01

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8" | PVC | Sch 40 | 0 | 30 |

Perforations:
Type perforation Slot
Size perforation .030
From 5 feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 30 feet

9. WATER LEVEL
Static water level 7' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GRIFFIN DEWATERING (Contractor)
Address 536 E MAITLAND (Contractor)
ONTARIO Ca 91761
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2150
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-26-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627