WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83506
Permit No.
Basin 212

NOTICE OF INTENT NO. 15880

1. OWNER City Of North Las Vegas
MAILING ADDRESS PO Box 4086
ADDRESS AT WELL LOCATION S.E. Corner Lola + Donna – North Las Vegas 2039 N LV Blvd

2. LOCATION SE ¼ NW ¼ Sec. 23 T. 20 N/S R. 61 E. County
PERMIT NO. (Issued by Water Resources) 139-23-201-013 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Unknown

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pulled Pumping Unit From Well –				
Attempt To Air Lift – Stopped @ 80'				
Video Log – Found Wood + Wires In Well				
Set Up Drill Rig – And Drilled To 195'				
Perforated Casing From 195' To Surface				
Attempted To Pull Casing – Casing Pulled Apart @ 15 Feet.				
Set Tremie Pipe @ 195' – Pumped 9 Yards Of Neat Cement To 4' Below Surface				
Backfilled Excavation At Well Top With Sand Slurry.				

DCNR/DWR Received MAR 21 2001 LAS VEGAS OFFICE

Date started 2-14-01, 19
Date completed 3-6-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was ~~drilled~~ Abandoned under my supervision and the report is true to the best of my knowledge.
Name B-L. Weaver Group, Inc (Contractor)
Address 8108 Bay Harbor Dr (Contractor)
Las Vegas NV. 89128
Nevada contractor's license number issued by the State Contractor's Board 035639
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2024(T2)
Signed David E. Munoz
By driller performing actual drilling on site or contractor
Date 3-14-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627