WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83517
Permit No.
Basin 162

NOTICE OF INTENT NO. 43692

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION LOT 202 6TH STREET
2580 E. 6th
Silver Springs

2. LOCATION NE 1/4 NW 1/4 Sec. 14 T 17 N/S R 25 E Lyon County
PERMIT NO. Issued by Water Resources
17-331-16 Parcel No.
Stockton Sub Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	20	20
BROWN CLAY		20	22	2
BROWN SAND		22	40	18
BROWN CLAY		40	80	40
BROWN SILT/CLAY		80	110	30
BROWN CLAY		110	120	10
BROWN SAND/GRAVEL	X	120	135	15

Date started 5/4/2000 , 19__
Date completed 6/1/2000 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	135	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+3	135

Perforations:
Type perforation MACHINE SLIT
Size perforation .08
From 128 feet to 132 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50' AQUAGUARD
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 40' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO DRILLING CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed [signature] By driller performing actual drilling on-site or contractor
Date 6/30/2000

USE ADDITIONAL SHEETS IF NECESSARY