WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83523
Permit No.
Basin 101

NOTICE OF INTENT NO. 44173

1. OWNER Lattin Farms
MAILING ADDRESS 1955 McLean Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1955 McLean Road,
Fallon, NV 89406

2. LOCATION SE 1/4 SW 1/4 Sec. 34 T 19N N/S R 28E E Churchill County
PERMIT NO. W-528 Issued by Water Resources
8-731-26 Parcel No.
Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [X] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown Clay		0	10	10
Brown Sand		10	40	30
Gray Sand		40	83	43
Gray Clay		83	85	2
Brown Sand		85	90	5
Brown Clay		90	99	9
Gray Sand		99	108	9
Gray Clay		108	120	12
Gray Sand		120	157	37
Gray Clay		157	165	8
Brown sand	XX	165	183	18

RECEIVED
00 DEC 22 AM 11:07
STATE ENGINEER'S OFFICE

Date started 08/16/2000, 19__
Date completed 08/19/2000, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80		1 hr

8. **WELL CONSTRUCTION**
Depth Drilled 183 Feet Depth Cased 183 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	183	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	183

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 177 feet to 183 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 183 feet

9. **WATER LEVEL**
Static water level 27 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 10/23/2000

USE ADDITIONAL SHEETS IF NECESSARY