

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83532
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 44847

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

1. OWNER MIKE CASEY/ANDERSON ADDRESS AT WELL LOCATION 2040 E. ANTELOPE
 MAILING ADDRESS 1550 S. ALLEN ROAD
FALLON, NV 89406
 2. LOCATION SW 1/4 SW 1/4 Sec. 20 T 17 N/S R 25 E LYON County
 PERMIT NO. 17-462-08 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------|--------------|------------|------------|------------|
| <u>AQUAGUARD SEAL</u> | | | | |
| <u>TOP SOIL</u> | | <u>0</u> | <u>1</u> | <u>1</u> |
| <u>BROWN SAND</u> | | <u>1</u> | <u>18</u> | <u>17</u> |
| <u>HARDPAN</u> | | <u>18</u> | <u>20</u> | <u>2</u> |
| <u>BROWN SAND</u> | | <u>20</u> | <u>35</u> | <u>15</u> |
| <u>GREY SAND</u> | | <u>35</u> | <u>40</u> | <u>5</u> |
| <u>BROWN SAND</u> | | <u>40</u> | <u>60</u> | <u>20</u> |
| <u>GREY SAND/CLAY</u> | | <u>60</u> | <u>100</u> | <u>40</u> |
| <u>BROWN CLAY</u> | | <u>100</u> | <u>110</u> | <u>10</u> |
| <u>BROWN SAND</u> | | <u>110</u> | <u>135</u> | <u>25</u> |
| <u>BLACK SAND</u> | <u>X</u> | <u>135</u> | <u>140</u> | <u>5</u> |

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)

| | |
|------------------|----------------|
| From | To |
| <u>10</u> inches | <u>0</u> Feet |
| <u>8</u> inches | <u>50</u> Feet |
| _____ inches | _____ Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|--------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>12.9</u> | <u>.188</u> | <u>+2</u> | <u>140</u> |

Perforations:
 Type perforation MACHINE SLOT
 Size perforation .080
 From 136 feet to 139 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WELSCO CORP. Contractor
 Address P.O. BOX 888 Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 2/12/2001

Date started 12/16/2000, 19
 Date completed 1/20/2001, 19

7. WELL TEST DATA

| TEST METHOD: | Draw Down (Feet Below Static) | Time (Hours) |
|--|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift <u>20</u> G.P.M. | <u>1 HR</u> | |

RECEIVED
 01 FEB 22 PM 12:53
 STATE ENGINEER'S OFFICE