

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41579

1. OWNER DAN & Jeanette Hunter ADDRESS AT WELL LOCATION UNIT 4  
MAILING ADDRESS NE 34 Unit 522-6 Block 27 lot 7  
EIKO NV 89801 White Rock

2. LOCATION SE 1/4 SW 1/4 Sec 19 T 35 R 56 E EIKO County \_\_\_\_\_  
PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Caliche		2	4	2
Aluminum-clays		4	80	76
Fractured Granite		80	210	130
Sand Stone		215	308	98

8. WELL CONSTRUCTION  
Depth Drilled 308 Feet Depth Cased 308 Feet

HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
105/8 Inches \_\_\_\_\_ Feet 308 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>21</u>	<u>2.50</u>	<u>0</u>	<u>308</u>

Perforations:  
Type perforation slots  
Size perforation 1/8 x 6  
From 220 feet to 300 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50 feet  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 308 feet

9. WATER LEVEL  
Static water level 208 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality clear

Date started March 16 2001  
Date completed March 17 2001

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>16</u>	<u>0</u>	<u>4 hours</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HARD ROCK Exploration Inc. Contractor  
Address 1000 BARRINGTON AVE Contractor  
EIKO NV 89801

Nevada contractor's license number issued by the State Contractor's Board 0048915  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1670

Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 4-1-01