

OFFICE USE ONLY  
 Log No. 83587  
 Permit No. 419  
 Basin.....

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41577

1. OWNER DAN & Jennette Hunter ADDRESS AT WELL LOCATION UNIT 4  
 MAILING ADDRESS 11034 Unit 522-6 Block 27 lot 7  
EIKO NJ 09801 White Rock

2. LOCATION SE 1/4 SW 1/4 Sec 19 T. 35 N/S R. 56 E EIKO County

PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Caliche		2	4	2
Aluminum-chrys		4	80	76
Fractured Granite		80	210	130
Sand Stone	215	210	308	98

RECEIVED  
 OIMMY - APR 11 10  
 STATE ENGINEERING OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 308 Feet Depth Cased 308 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
105/8 Inches 0 Feet 308 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>21</u>	<u>2.50</u>	<u>0</u>	<u>308</u>

Perforations:  
 Type perforation slots  
 Size perforation 1 3/8 x 6  
 From 220 feet to 300 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 308 feet

Date started March 16 2001  
 Date completed March 17 2001

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>16</u>	<u>0</u>	<u>4 hours</u>

9. WATER LEVEL  
 Static water level 208 feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HARD ROCK Exploration Inc Contractor  
 Address 1000 Barrington Ave Contractor  
EIKO NJ 09801

Nevada contractor's license number issued by the State Contractor's Board 0048915  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1670

Signed Scott Decker  
 By driller performing actual drilling on site or contractor  
 Date 4-1-01