

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 3569
Permit No. 87
Basin 87
NOTICE OF INTENT NO 45815
8770 Lakeside Drive

1. OWNER **Louri Kalanges**
MAILING ADDRESS **8770 Lakeside Drive**
Reno NV

ADDRESS AT WELL LOCATION

2. Location **NW 1/4 NW 1/4 Sec 12 T 18N R 19E Washoe County**
PERMIT NO. **PARCEL NO. 040-650-22** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE
 New Well Replace Recondition | Domestic Irrigation Test | Cable Rotary RVC
 Deepen Abandon Other | Municipal/Industrial Monitor Stock | Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobbles boulders with coarse sands & gravel.		0	28	28
Tan yellow brown red coarse sands & gravels with tan clay lenses.		28	155	127
Fine sands & gravel.		155	196	41

8. WELL CONSTRUCTION

Depth Drilled		Depth Cased	
11	feet	0	feet

HOLE DIAMETER (BIT SIZE)

From	To
0	196
feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	196

Perforations::

Type Perforation	Factory
Size perforation	Screen 50
From 176	feet to 196
From	feet to

Surface Seal YES No Seal Type:
 Depth of Seal 104 feet Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 154 feet to 104 feet

RECEIVED
 DIVISION OF WATER RESOURCES
 90-1111-06

Date started **6-11 -01**
Date completed **6-13 -01**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
30	190	4		

9. WATER LEVEL
 Static water level 0 feet below land surface
 Artesian flow 30 GPM 0 P.S.I.
 Water Temperature cold Degrees F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **1511**
 Signed *Steve McKay*
 By driller performing actual drilling on site or contractor
 Date **6-15 -01**