

OFFICE USE ONLY  
 Log No. 83571  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF IN \_\_\_\_\_ 45264

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Anglo Gold Mines ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS H.C. 31-28 Elko NV 89801 Mtn City Hwy 50 miles N. of Elko

2. LOCATION SE 1/4 SE 1/4 Sec. 33 T. 41 N. 45 E County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  PVC  
 Air  Other Case

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tailings dam Red silt		0'	115'	115'
Wet Red in color changing				
Very hard cemented gravel and sands		115'	120'	5'
Very hard silt & sand very little Gravel very tight clay stringers		120'	150'	30'
moist silty sand hard to drill very tight increasing clay		150'	170'	20'
Unconsolidated Gravel and wet water strata		170'	175'	5'
silt clay 60% silt 40% clay very tight		175'	180'	5'

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
6" Inches 0 Feet 180 Feet  
8" Inches 0 Feet 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7"		sch 40	0	146

Perforations:  
 Type perforation Factory Horizontal  
 Size perforation 020  
 From 146 feet to 176 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 20'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No Note Pro-pac  
 From 146 feet to 176 feet

9. WATER LEVEL  
 Static water level N/A feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ala' Boart Loneyer Contractor  
 Address P.O. Box 7000 Dayton NV 89403 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2168  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5/20/01

Date started 5/17/01, 19\_\_\_\_\_  
 Date completed 5/17/01, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

RECEIVED  
 01 MAY 23 PM 12:22  
 STATE ENGINEERS OFFICE