

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST 15262

1. OWNER Anglo Gold mines ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HC 31-78 Elko NV 89821 Inter city Hwy, 50 miles N of Elko

2. LOCATION NE 1/4 NW 1/4 Sec 4 T 40 S R 54 E County _____

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tailings pond 90% silt 10% sand Red in color Very wet		0	60'	60'
Tailings pond 75% silt 25% sand Green in color Very wet		60'	72'	12'
Alluvium silt, sand Gravel very hard & tight		72'	123	51'
Uncolored silt and sand with lots of gravel		123	147	24'
low permeability, silty sand w/ gravel traces of clay		147	150	3'

8. WELL CONSTRUCTION
 Depth Drilled 150' Feet Depth Cased 150' Feet
 HOLE DIAMETER (BIT SIZE)
 From To
4" Inches 0' Feet 150' Feet
6" Inches 0' Feet 150' Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>sch 40</u>	<u>sch 40</u>	<u>0</u>	<u>130'</u>

Perforations:
 Type perforation Factory Horizontal
 Size perforation 020
 From 130 feet to 150' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 20' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 125' feet to 150' feet

9. WATER LEVEL
 Static water level N/A feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5/15/01, 19_____
 Date completed 5/15/01, 19_____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boart Longyear Contractor
 Address P.O. Box 1000 Dayton NV 89403 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2168
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5/20/01