WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83576
Permit No.
Basin 64

NOTICE OF INTENT NO. 34847

1. OWNER Morrison-Warren Partnership ADDRESS AT WELL LOCATION N/A
MAILING ADDRESS PO Box 100
Valmy Station NV 89438

2. LOCATION SW ¼ NW ¼ Sec. 27 T. 34 N/S R. 43 E. Humboldt County
PERMIT NO. 66110 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	15	
Cemented gravel		15	70	
Clay w/gravel		70	130	
Cemented Rock		130	160	
gravel w/s Clay		160	210	
Rock w/s gravel		210	235	
Clay/gravel w/s		235	280	
Cemented Rock		280		
gravel w/s Clay		280	325	
Clay		325	330	
gravel w/s Clay		330	370	

Date started 3-19-01, 19
Date completed 4-15-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150		4

8. WELL CONSTRUCTION
Depth Drilled 370 Feet Depth Cased 370 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4 Inches		0 Feet	50 Feet
10 Inches		50 Feet	370 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 in		.250	0	370

Perforations:
Type perforation Factory 1/8 X 3 in
Size perforation
From 290 feet to 370 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 370 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bunkerhoff Pump & Drilling Co. (Contractor)
Address PO Box 026 (Contractor)
WWMC. NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1161
Signed (Driller performing actual drilling on site or contractor)
Date 5-15-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627