WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83618
Permit No.
Basin

NOTICE OF INTENT NO. 43118

1. OWNER Crystal Bay Club
MAILING ADDRESS 24 State Route 28 Crystal Bay Nev. 89402
ADDRESS AT WELL LOCATION 24 State Route 28 Crystal Bay Nev. 89402

2. LOCATION NW ¼ NE ¼ Sec. 30 T. 16 N/S R. 18 E. WASHOE County
PERMIT NO. Issued by Water Resources | Parcel No. 123-042-01 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW #1

Material	Water Strata	From	To	Thickness
Well was in Gravel After cover was Removed. Overdrilled Casing to 30 Feet And Pressure grouted hole from Bottom to top.				

RECEIVED
04 APR -9 AM 10:56
STATE ENGINEER
DIVISION OF WATER RESOURCES

Date started 04 28, 1900
Date completed 4 28, 1900

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	Feet	0	30 Feet
Inches	Feet		Feet
Inches	Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	Factory	0.20	0	30

Perforations:
Type perforation Factory
Size perforation 0.20
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 30
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 6 feet to 30 feet

9. WATER LEVEL
Static water level 13 Feet feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 60.0 °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jerry Anderson Exploration Drilling Contractor
Address 1630 Belford Contractor
Reno Nev. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2139
Signed By driller performing actual drilling on site or contractor
Date 2/13/01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627