

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 83638  
 Permit No. \_\_\_\_\_  
 Basin 162

NOTICE OF INTENT NO. 22300

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Nationwide ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3141 W. Windsong 3141 W. Windsong  
Pahrump, NV 89048

2. LOCATION NE 1/4 NE 1/4 Sec. 13 T 20S N/S R 52E E Nye County  
 PERMIT NO. \_\_\_\_\_ 41-402-05 Golden Springs Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well Replace  Recondition  
 Deepen Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown loam		0	2	2
grey clay		2	16	14
brown clay	x	16	88	72
grey clay	x	88	140	52

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>11</u>	<u>0</u>	<u>140</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation sawcut  
 Size perforation .188

From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 120 feet to 140 feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

Date started 5/30/01 \_\_\_\_\_ 19\_\_\_\_  
 Date completed 5/30/01 \_\_\_\_\_ 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-17-01

