WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83642
Permit No.
Basin 162

NOTICE OF INTENT NO. 22303

1. OWNER Ron Murphy
MAILING ADDRESS 2061 E. Panoroma
Nye, NV 89048

ADDRESS AT WELL LOCATION 2061 E. Panoroma

2. LOCATION NW 1/4 SW 1/4 Sec. 13 T 20S N/S R 53 E Nye County
PERMIT NO. _____ Issued by Water Resources | 35-271-47 Parcel No. | Nye Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay with gravel	x	0	280	280

Date started 6/20/01 , 19__
Date completed 6/20/01 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280+1 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	280 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	280

Perforations:
Type perforation sawcu
Size perforation .188
From 240 feet to 280 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 125 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed [signature] By driller performing actual drilling on-site or contractor
Date 7-26-01

DCNR-HEALTH
RECEIVED
JUL 30 2001
LAS VEGAS OFFICE