

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 83731
 Permit No. 91
 Basin I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 4562

1. OWNER American Enviro Resources Inc. - Verdi Water ADDRESS AT WELL LOCATION Verdi Meadows Utility
 MAILING ADDRESS 1129 Hunter Lake Dr. 1850 Old Hwy
Reno, NV 89509 40

2. LOCATION NE 1/4 SW 1/4 Sec. 9 T 19N N/S R 18E E Washoe County
 PERMIT NO. Waiver W-538 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cobbles & clay		0	50	50
gray clay		50	65	15
gravel		65	70	5
sandy gray clay		70	90	20
basalt		90	100	10
basalt & gravel		100	180	80
brown volcanic		180	190	10
gray volcanics		190	390	200
basalt		390	490	100
green clay		490	495	5
basalt		495	500	5
Pumped grout from 500 ft. to 400 ft. to abandon bottom portion of well		400		
			500	100

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
15 Inches 0 Feet 100 Feet
9-7/8 Inches 100 Feet 400 Feet
6-1/8 Inches 400 Feet 500 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8-5/8</u>		<u>.250</u>	<u>+2</u>	<u>100</u>

Perforations:
 Type perforation mill slot
 Size perforation .125
 From 100 feet to 400 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 400 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 4/21/01, 19____
 Date completed 5/18/01, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>220</u>	<u>263</u>	<u>72 hrs</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 5/28/01