WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83801
Permit No.
Basin 87

NOTICE OF INTENT NO. 42093

1. OWNER Washoe County Dept of Water Resources
MAILING ADDRESS 4930 Energy way Reno NV 89502
ADDRESS AT WELL LOCATION Broadhead Park at the N. End of Parkst

2. LOCATION SW ¼ NW ¼ Sec 12 T 19 N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Back Fill material along		0	19'	19'
river Bank mix of				
gravel and Sands				
40% Silty 60% Sand		19'	23'	4'
Moist, Firm, Brownish Grey				
Mix of gravels and Sands	24.5	23'	31	8'
few Cobbles "Wet"				
30% Gravel 40% Sand		31'	38	7'
30% Silt				
60% Sand 40% Silt Damp		38'	41'	3'
Brownish Red "Firm"				

Date started 3/8/01, 19
Date completed 3/08/01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 41 Feet Depth Cased 41 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
4" Inches		Ø Feet	41 Feet
6" Inches		Ø Feet	41 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40	Ø	20.5

Perforations:
Type perforation Horizontal, Factory
Size perforation 020
From 20.5 feet to 40.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 12.5
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 16' feet to 41' feet

9. WATER LEVEL
Static water level 24.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan Jackson / Boart Longyear (Contractor)
Address P.O. Box 1000 Dayton NV, 89403 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2168
Signed (By driller performing actual drilling on site or contractor)
Date 4/09/01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627