

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42098

1. OWNER Washoe County Dept of Water Resources ADDRESS AT WELL LOCATION Prosperity St S. side of st at corner of Prosperity & Sunshines
 MAILING ADDRESS 4930 Energy Way Reno NV 89502

2. LOCATION SW 1/4 SW 1/4 Sec. 7 T. 19 N. R. 20 E. Washoe County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Self

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel with Cabbles		0	6.5	6.5
Very loose Granite Cabbles		1		
Med Grained Sand Well		6.5	10'	3.5'
Sorted Dark Brown				
Sandy Gravel Very loose		10'	24'	14'
Coarse Gravel Dark Greyish				
Coarse Sand w/ Gravel		24'	38'	14'
Very loose Comp Dark Brown				
Granite Boulders	39	38'	43	5'
Silty Sand Gravel 20-30% silt 50% sand "wet"		43'	55'	12'
Med grained Sand, light Brown				
Grey Gravel				

8. WELL CONSTRUCTION
 Depth Drilled 56 Feet Depth Cased 56' Feet
 HOLE DIAMETER (BIT SIZE)
 From To
4" Inches Ø Feet 56' Feet
6" Inches Ø Feet 56' Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40	0	35.5
				35.5

Perforations:
 Type perforation Factory
 Size perforation Ø20
 From Ø 35.5 feet to 55.5 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 27' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 20 feet to 56 feet

9. WATER LEVEL
 Static water level 39 feet below land surface
 Artesian flow: _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 3/23/01, 19_____
 Date completed 3/23/01, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Althas Jackson / Boart Longyear Contractor
 Address P.O. Box 1000 Dayton NV 89403 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2168
 Signed Althas Jackson
 By driller performing actual drilling on site or contractor
 Date 4/9/01