WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83808
Permit No.
Basin 51

NOTICE OF INTENT NO. 38345

1. OWNER Union Pacific Railroad SP-26
MAILING ADDRESS 1416 Dodge Street, Room 930
Omaha, NB 68179-0930

ADDRESS AT WELL LOCATION 413 Main Street, Carlin
NV 89822

2. LOCATION SE 1/4 SE 1/4 Sec. 27 T 33N N/S R 52E E Elko County
PERMIT NO. N/A (Issued by Water Resources) | 051 N33 E52 27 (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
No original well driller's report was found by DWR or our client. Therefore, construction details have been omitted. Well had been damaged at surface by a snowplow.				
Surface monument was removed, and the well filled with neat cement from T.D. to surface.				
Used 0.3 cu. ft. of neat cement to fill casing, 0.7 cu. ft. to fill hole left when monument was removed.				

Date started 3/22/2001, 19__
Date completed 3/22/2001, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 13.24 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	13.24

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 7.55 feet below land surface
Artesian flow N/A G.P.M. ____ P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2039
Signed Dennis Robblee (By driller performing actual drilling on-site or contractor)
Date 3/23/01

USE ADDITIONAL SHEETS IF NECESSARY

B.S.L