WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83810
Permit No.
Basin

NOTICE OF INTENT NO. 38346

1. OWNER Callamont Estates/Washoe County [redacted]
MAILING ADDRESS P.O. Box 11130
Reno, NV 89520

ADDRESS AT WELL LOCATION Callahan Ranch Road,
Reno, NV.

2. LOCATION NE 1/4 SW 1/4 Sec. 11 T 17N N/S R 19E E Washoe County
PERMIT NO. W-539 (Issued by Water Resources) | 47-141-08 (Parcel No.) | Callamont Estates (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [✓] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Fld Rvs

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Sand & gravel		0	290	290
Andesite		290	330	40
Sand & gravel		330	440	110
Clay		440	450	10
Sand & gravel		450	500	50
Andesite		500	540	40
Sand & gravel		540	610	70
Andesite		610	630	20
Sand & gravel		630	680	50
Andesite		680	700	20
Sand & gravel		700	770	70
Andesite		770	790	20
Sand & gravel		790	910	120
eel plate welded				
between 14" and 22"				
casings at surface.				

Date started 4/4/2001, 19__
Date completed 4/10/2001, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
487	82 feet	1 Hour

8. **WELL CONSTRUCTION**
Depth Drilled 910 Feet Depth Cased 900 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
38	Inches	0	Feet	13	Feet
29	Inches	13	Feet	100	Feet
19	Inches	100	Feet	910	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
33	130.67	0.375	0	13
22	86.61	0.375	0	100
14	54.67	0.375	+2	901.46

Perforations:
Type perforation Wire Wrap
Size perforation 0.080"
From 400 feet to 540 feet
From 580 feet to 900 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 0 feet to 910 feet

9. **WATER LEVEL**
Static water level 145 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2115
Signed Austin Wilcox (By driller performing actual drilling on-site or contractor)
Date 4/18/01

USE ADDITIONAL SHEETS IF NECESSARY

BST.C