WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93813
Permit No.
Basin 88

NOTICE OF INTENT NO. 38346

1. OWNER Callamont Estates/Washoe County CT-1
MAILING ADDRESS P.O. Box 11130
Reno, NV 89520

ADDRESS AT WELL LOCATION Callahan Ranch Road,
Reno, NV.

2. LOCATION NE 1/4 SW 1/4 Sec. 11 T 17N N/S R 19E E Washoe County
PERMIT NO. W-~~359~~ -539 (Issued by Water Resources) | 47-141-08 (Parcel No.) | Callamont Estates (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Flooded

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	280	280
Andesite		280	340	60
Sand & gravel		340	420	80
Andesite		420	438	18
Sand & gravel		438	500	62
Andesite		500	520	20
Sand & gravel		520	600	80
Andesite		600	620	20
Sand & gravel		620	640	20
Andesite		640	680	40
Sand & gravel		680	780	100
Andesite		780	800	20
Sand & gravel		800	810	10
Neat cement pumped		0		
between 13" and 6"				
casings			100	100

RECEIVED 01 APR 13 AM 11:08 STATE ENGINEER'S OFFICE

Date started 3/29/2001 , 19__
Date completed 4/2/2001 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
90	21.99	1 Hour

8. WELL CONSTRUCTION
Depth Drilled 810 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
19	Inches	0	Feet	60	Feet
12.25	Inches	60	Feet	810	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
13.375	68.25	0.375	0	60
6.675	17.02	0.250	+2	800

Perforations:
Type perforation Double Row Slot
Size perforation 0.080" X 3"
From 400 feet to 420 feet
From 440 feet to 600 feet
From 680 feet to 800 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 810 feet

9. WATER LEVEL
Static water level 144.5 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2115
Signed Dustin Wilcox (By driller performing actual drilling on-site or contractor)
Date 4/9/01

USE ADDITIONAL SHEETS IF NECESSARY