WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83827
Permit No.
Basin

NOTICE OF INTENT NO. 4-19[illegible]

1. OWNER Howard Hoffman
MAILING ADDRESS P.O. Box 22, Elko, NV 89801
ADDRESS AT WELL LOCATION None

2. LOCATION SW ¼ SW ¼ Sec. 30 T. 34 N/S R. 56 E. Elko County
PERMIT NO. N/A (Issued by Water Resources) | Parcel No. 000-214-005 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay lifrock Brown		0	12	12
Yellow clay		12	40	28
Sandy clay	Seep	37	38	1
Fossil bed		38	41	3
Broken shale		41	77	36
Fault gouge		77	78	1
Broken shale		78	90	12
Fault gouge	Air	90	107	16
Shale broken		107	114	
TD 114				
Short [illegible]				
[illegible]				

Date started 04 [illegible], 19__
Date completed 4 [illegible], 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	25	8

8. WELL CONSTRUCTION
Depth Drilled 114 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	54 Feet
8 Inches		54 Feet	114 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.52	.188	+1.2	114

Perforations:
Type perforation Torch cut
Size perforation 1/4 x 4
From feet to feet
From 64 feet to 104 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 92 feet to 114 feet

9. WATER LEVEL
Static water level 32 feet below land surface
Artesian flow None G.P.M. P.S.I.
Water temperature 54 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nutt Drilling Co. (Contractor)
Address 203 Pine St. (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 1119
Nevada driller's license number issued by the Division of Water Resources, the on-site driller [illegible]
Signed [illegible] (By driller performing actual drilling on site or contractor)
Date 05/14/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627