WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83846
Permit No.
Basin 89

NOTICE OF INTENT NO. 44497

1. OWNER Paul Mijanovich
MAILING ADDRESS 7420 Bryan Canyon Rd
Carson City, NV 89704

ADDRESS AT WELL LOCATION 7420 Bryan Canyon Rd.

2. LOCATION SW 1/4 SW 1/4 Sec. 23 T 16N N/S R 19E E Washoe County
PERMIT NO. WaCo#6848 (Issued by Water Resources) 055-292-30 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Slightly fractured Tan D.G.	x	190	210	20
Quartz, multi colored rock	x	210	241	31
Gray granite		241	251	10
White quartz/ gray granite		251	263	12
Fractured gray granite	x	263	300	37

RECEIVED
01 JUN -1 AM 11:17
STATE ENGINEER'S OFFICE

Date started 5/22/2001, 19__
Date completed 5/22/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	29	21	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	190	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	180	300

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 240 feet to 260 feet
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 5/25/01

USE ADDITIONAL SHEETS IF NECESSARY