

OFFICE USE ONLY
 Log No. 83849
 Permit No. 99
 Basin
 NOTICE OF INTENT NO. 44303

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dave Keever ADDRESS AT WELL LOCATION: 80 Cowhide Cir Reno NV 89506
 MAILING ADDRESS 17000 Whitewood Sparks NV 89434
 2. LOCATION SE 1/4 SW 1/4 Sec 11 T. 23 S. R. 18 E. Washoe County Rancho Sierra
 PERMIT NO. 079-18-203 Parcel No. Subdivision Name
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Topsoil		0	3	3
Sand		3	70	67
Clay		70	73	3
Sand		73	150	77
Clay		150	160	10
Sand		160	240	80

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>3/16</u>	<u>24</u>	<u>240</u>

Perforations:
 Type perforation 3" x 60 TH
 Size perforation _____
 From 200 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 240 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow 6 G.P.M. NA P.S.I.
 Water temperature cold °F Quality Fair

Date started 3/19/01
 Date completed 3/21/01

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>140</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Oleviski Drilling & Pump Contractor
 Address 15045 Red Rock Rd Reno NV 89506
 Nevada contractor's license number 50343 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
 Signed John F. Oleviski
 By driller performing actual drilling on site or contractor
 Date 3/29/01

Washoe County Permit # 6808