WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83855
Permit No.
Basin 107

NOTICE OF INTENT NO. 33438

1. OWNER William + Judith Jacobson
MAILING ADDRESS P.O. Box 47 Wellington, Nev 89444
ADDRESS AT WELL LOCATION 26 Walters Lane Wellington, Nev 89444

2. LOCATION E 1/2 1/4 NE 1/4 Sec. 23 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. _____ Issued by Water Resources | 10-321-11 Parcel No. | Schwake Ranch Estates Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D G Top Soil		0	20	20
Hardpan Dirt		20	32	12
Sandy Clay		32	45	13
Clay stratta		45	55	10
Sand+gravel	yes	55	125	70

RECEIVED 01 MAY 22 AM 10:36 STATE ENGINEER'S OFFICE

Date started April 3, 2001 ~~19~~
Date completed May 7, 2001 ~~19~~

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	15	3

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 Inches	50 Feet	125 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	125

Perforations:
Type perforation Factory Saw Slott
Size perforation 3/32 X 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Contractor
Address P.O. Box 92 Smith Nev 89430 Contractor
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date 5-21-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627