

OFFICE USE ONLY  
 Log No. 83857  
 Permit No. 87  
 Basin 87

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 45298

1. OWNER Washoe County Dept. of Wtr. Resources ADDRESS AT WELL LOCATION Crompton St. midway between Holcomb & Wheeler  
 MAILING ADDRESS 4930 Energy Way Reno NV 89502

2. LOCATION SW 1/4 NW 1/4 Sec. 13 T. 19 N/R 19 E. Washoe County  
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Service

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Large rounded cobbles and boulders silty brown sand matrix dry		0	<del>14</del> 34'	34'
Loose tanish brown silty fine sand small gravel		34'	36	2'
Back to large rounded cobbles and boulders silty brown sand matrix	55'	36	65	29'
Loose Tan/brown sandy gravel		65	67	2'
Rounded cobbles boulders sandy matrix		67	72	5'
Coarse sands small amounts fine sand some iron stained streaks		72	73'	

8. WELL CONSTRUCTION  
 Depth Drilled 73 Feet Depth Cased 70 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
4" Inches 0 Feet 73 Feet  
6" Inches 0 Feet 70 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40	0	50

Perforations:  
 Type perforation Factory & Horizontal  
 Size perforation 020  
 From 50 feet to 70 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 40'  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 45 feet to 70 feet

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear Contractor  
 Address P.O. Box 1000 Dayton NV 89403 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2168  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 4/9/01

Date started 3/26/01, 19\_\_\_\_  
 Date completed 3/26/01, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)