

OFFICE USE ONLY  
 Log No. 83858  
 Permit No. 877  
 Basin 877

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42099

1. OWNER Washoe County Dept of Wtr Resources ADDRESS AT WELL LOCATION Haskell St Infront of 853 Haskell St  
 MAILING ADDRESS 4930 Energy Way Reno NV 89502

2. LOCATION SE 1/4 NE 1/4 Sec 14 T 19 N 19 E County \_\_\_\_\_  
 PERMIT NO. 11-331-8 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Surface

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Coarsely silt Sand m.x</u>		<u>0</u>	<u>9'</u>	<u>9'</u>
<u>Damp Dark to light Brown</u>				
<u>Sand silt m.x light Brown</u>	<u>10</u>	<u>9'</u>	<u>11'</u>	<u>2'</u>
<u>Sand gravel m.x little</u>		<u>11'</u>	<u>21'</u>	<u>10'</u>
<u>or no Fines</u>				
<u>Boulder</u>		<u>21'</u>	<u>22.5'</u>	<u>1.5'</u>
<u>Silty Sand light Brown</u>		<u>22.5'</u>	<u>26.5'</u>	<u>4'</u>
<u>Low plasticity</u>				
		<u>MAX</u>		

8. WELL CONSTRUCTION  
 Depth Drilled 26.5 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>4"</u>	<u>0</u>	<u>26.5</u>
<u>6"</u>	<u>0</u>	<u>25</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>sch 40</u>	<u>0</u>	<u>4.5</u>

Perforations:  
 Type perforation Factory  
 Size perforation 020

From 4.5 feet to 24.5 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 1.5

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 3.5 feet to 25 feet

Date started 3/21/01, 19\_\_\_\_  
 Date completed 3/21/01, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 10' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart longyear Contractor  
 Address P.O. Box 1000 Dayton NV 89403 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2168

Signed Nate Johnson  
 By driller performing actual drilling on site or contractor  
 Date 4/8/01