

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83860
 Permit No. _____
 Basin 107
 NOTICE OF INTENT NO. **4491**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

1. OWNER Greg & Linda Garmong
 MAILING ADDRESS 1341 Stephanie Way
Minden, NV 89423
 ADDRESS AT WELL LOCATION #11 Dee Court Smith
Valley
 2. LOCATION NW 1/4 SE 1/4 Sec. 27 T 11N N/S R 24E E Lyon County
 PERMIT NO. 10-581-13 Issued by Water Resources Parcel No. Hudson Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
fine to med fine sand	no	0	55	55
Sandy clay	no	55	77	22
Med. fine sand	no	77	97	20
Sandy clay	no	97	132	35
Unsorted sand and gravel	no	132	174	42
Boulders and cobbles	yes	174	190	16
Brown clay	no	190	196	6
med. grain sand	yes	196	220	24

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>60</u> Feet
<u>9 7/8</u> Inches	<u>60</u> Feet	<u>220</u> Feet

 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>220</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 1/8 6 row
 From 180 feet to 220 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 147 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eddco Exploration Inc. Contractor
 Address 7780 Curry Rd. Contractor
Fallon, Nv. 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 4/12/2001

Date started 4/9/2001, 19____
 Date completed 4/11/2001, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>+ 45</u>	<u>1 hr.</u>	

RECEIVED
 01 MAY 15 AM 11:12
 STATE ENGINEERS OFFICE