

OFFICE USE ONLY
 Log No. 83867
 Permit No. 87
 Basin. 87
 NOTICE OF INTENT NO. 45058

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER RAY YORK ADDRESS AT WELL LOCATION Woodchuck Drive
 MAILING ADDRESS 2000 Shair Drive Reno, Nevada 89509
 ADDRESS AT WELL LOCATION Woodchuck Drive Reno, Nevada 89509
 2. LOCATION SE 1/4 SE 1/4 Sec 19 T 19N N/S R 19 E Washoe County
 PERMIT NO. 041-051-21 Juniper Hills Area Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown sandy clay some smaller boulders		1	2	1
Multi color sandy clays		2	41	39
Dark brown sandy clay		41	51	10
Light brownsandy clay		51	85	34
Reddish brown sandy clays		85	88	3
Yellow sandy clays		88	95	7
Multi color sandy clays		95	144	49
Brown sandy clays		144	165	21
Brown sandy clay, some volcanic gravels		165	195	30
Brown sandy clays		195	319	124
Gray sandy clays		319	355	36
Soft zone (Black sand app 5 GPM)	X	355	363	8
Gray sandy clays		363	414	51
Soft zone	X	414	419	5
Gray sandy clays		419	445	26
Soft zone	X	445	462	17
Gray sandy clays		462	473	11

8. WELL CONSTRUCTION
 Depth Drilled 473 Feet Depth Cased 473 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 473 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	473

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 348 feet to 368 feet
 From 408 feet to 428 feet
 From 448 feet to 468 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 473 feet

9. WATER LEVEL
 Static water level 315 feet below land surface
 Artesian flow _____ G.P.M. 24.8 P.S.I.
 Water temperature cold °F Quality clear

Date started May 3, 2001, 19____
 Date completed May 7, 2001, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>24.8</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date May 8, 2001