WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 838166
Permit No.
Basin 87

NOTICE OF INTENT NO. 42095

1. OWNER Washoe County Department of Water Resources
MAILING ADDRESS 4930 Energy Way
Reno, NV. 89821

ADDRESS AT WELL LOCATION East Corner of Sunshine Lane and Mill Street.

2. LOCATION SW ¼ SW ¼ Sec. 7 T 19 N/S R 20 E Washoe County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Cobbles		0'	20'	20'
Coarse Sand & Cobbles		20'	80'	60'
Clayey Sand		80'	91'	11'
Coarse Sandy Gravel		91'	105'	14'
Clayey Silt		107'	111'	4'
Coarse Sandy Gravel		111'	170'	59'
Clay		170'	171'	1'
Sandy Gravel		171'	184'	13'
Medium Cobbles		184'	188'	4'
Silty Sandy Gravel		188'	250'	62'
Brown Stiff Clay		250	262'	12'
Clayey Gravel		262'	296'	34'
Gravels		296'	324'	28'
FINE SAND		324'	325'	1
Brown loose Gravel		325'	345'	20'
Silty Clay		345	350'	5'

RECEIVED 01 MAY 23 PM 12:21 DIVISION OF WATER RESOURCES

Date started 4-23-01, 19
Date completed 4-27-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 350' Feet Depth Cased 350' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8" Inches	0' Feet	150' Feet
5½" Inches	150' Feet	350' Feet
6" O.D Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch. 80'	+5'	347'

Perforations:
Type perforation Factory Cut
Size perforation 0.020'
From 347' feet to 327' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0'-23' Cement Grout
Placement Method: ☑ Pumped 23'-313' Quick Grout ☐ Poured 313'-318' Bent. Pellets
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 318' feet to 347' feet

9. WATER LEVEL
Static water level 53' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phillip Cramer for Boart Longyear (Contractor)
Address 32 Stokes Dr. Dayton, NV. 89403 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2148
Signed Phillip E. Cramer (By driller performing actual drilling on site or contractor)
Date 5-9-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627