

OFFICE USE ONLY
Log No. 83849
Permit No. 99
Basin.....
NOTICE OF INTENT NO. 44303

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dave Keever ADDRESS AT WELL LOCATION 80 Cowhide Cir Reno NV 89506
MAILING ADDRESS 17000 Whitewood Sparks NV 89434
2. LOCATION SE 1/4 SW 1/4 Sec 11 T 23 R 18 E Washoe County
PERMIT NO. 078-18-203 Subdivision Name Rancho Sierra

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Top soil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Sand</u>		<u>3</u>	<u>70</u>	<u>67</u>
<u>Clay</u>		<u>70</u>	<u>73</u>	<u>3</u>
<u>sand</u>		<u>73</u>	<u>150</u>	<u>77</u>
<u>Clay</u>		<u>150</u>	<u>160</u>	<u>10</u>
<u>sand</u>		<u>160</u>	<u>240</u>	<u>80</u>

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet
HOLE DIAMETER (BIT SIZE)
From 11 Inches To 0 Feet 240 Feet
Inches..... Feet..... Feet
Inches..... Feet..... Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>3/16</u>	<u>2+</u>	<u>240</u>

Perforations:
Type perforation 3" x 60 TH
Size perforation.....
From 200 feet to 240 feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 100' Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 100 feet to 240 feet

9. WATER LEVEL
Static water level..... feet below land surface
Artesian flow 6 G.P.M. NA P.S.I.
Water temperature cold °F Quality Fair

Date started 3/19/01
Date completed 3/21/01

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>140</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olencki Drilling & Pump Contractor
Address 15045 Red Rock Rd Contractor
RENO NV 89506
Nevada contractor's license number 50343 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1656
Signed John F. Olencki
By driller performing actual drilling on site or contractor
Date 3/29/01