

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83902
 Permit No. _____
 Basin 76

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45889

1. OWNER MARGARET MANSFIELD
 MAILING ADDRESS 1500 RANCHO DRIVE
FERNLEY, NV 89408

ADDRESS AT WELL LOCATION 1500 RANCHO DRIVE

2. LOCATION SE 1/4 SW 1/4 Sec. 19 T 20 N3 R 25 E CHURCHILL County

PERMIT NO. N/A Issued by Water Resources Parcel No. 020-381-01 Subdivision Name N/A

3. WORK PERFORMED
 New Well
 Deepen
 Replace
 Abandon
 Recondition
 Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
CLAY COBBLES		1	15	14
BR CLAY		15	23	8
M.C. GRAVELS		23	35	12
BR CLAY		35	40	5
MC GRAVELS		40	70	30
BR CLAY		70	72	2
MC GRAVELS	X	72	101	29

Replaced By Well
 Log 124392

Plugged By Well
 Log 124393

RECEIVED
 01 JUN 25 AM 11:40
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 101 Feet Depth Cased 101 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10 3/4	0	50
6 5/8	50	101

CASING SCHEDULE

Size O.D. (Inches)	Weight/Pt. (Pounds)	Well Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	101

Perforations:
 Type perforation HOLTE PERFORATOR
 Size perforation _____

From	To
05 feet	09 feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 57'4" feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WERLSCO CORP. Contractor
 Address P. O. BOX 888 Contractor
FALLON, NV 89408

Date started 5/14/2001 . 19__
 Date completed 5/28/2001 . 19__

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30 GPM</u>		<u>1 HR</u>

Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 6/20/2001